



FIRE MARSHAL'S DIVISION

121 Connecticut Avenue ■ Norwalk, CT 06854 ■ (203) 854-0244
Email: FDPrevent@norwalkct.org



STANDARD REGULATIONS FOR OUTDOOR AMUSEMENTS

1. Name of Public Event: _____
2. Location of Event: _____
3. Date of Event: _____

4. **EMERGENCY VEHICLE ACCESSIBILITY:**

- a. Posting of No Parking Streets or Areas: As outlined by DPW/NTA
- b. Posting of Closed-Off Streets: As outlined by DPW/NTA

5. Type of cooking equipment/source of fuel:

Propane Gas _____ Electrical Stove _____ Charcoal _____

- a. Propane Gas – ONLY U.L. Listed hose or piping can be used for propane gas supply lines.

NOTE: EXCEPTION – Copper tubing may be used vertically from the propane tank into the hose or piping, or from the supply line vertically into the cooking equipment.

- b. Hose or piping must be protected against physical damage. (i.e., underground, carpeting used with wood studs, etc.
- c. Propane tanks shall be a minimum of ten feet (10') away from open flames and tents. Also, a shut-off is required in a gas supply line.
- d. Propane tanks shall be properly secured.
- e. Installation of propane tanks and connection to cooking equipment used must be done by an approved vendor.
- f. All electrical equipment shall be a minimum of 6" to 8" high off the ground. i.e., refrigerators, freezers, stoves, etc.
- g. Each cooking tent shall be equipped with a minimum of one (1) 10 lb. ABC type fire extinguisher. Large cooking areas may need several, subject to the Fire Marshal's discretion.
- h. Other cooking equipment shall be secured and protected against the public being accidentally burned.

6. Certification on tents shall be required by the Fire Marshal seven (7) days prior to the event.
7. The tops of all tent spikes shall be protected. i.e., covered with foam, heating tape or stake cap covers.
8. Fire watch required? _____
9. Engine Co. Required? _____
10. Emergency Lighting and Exit signs needed? _____

NOTE: AREA SHALL BE DESIGNATED BY THE FIRE MARSHAL.

Organization: _____ Signature: _____
Director or Authorized Representative

Fire Marshal's Signature: _____