



Public Health
Prevent. Promote. Protect.
Norwalk Health Department

CITY OF NORWALK, HEALTH DEPARTMENT

www.norwalkhealth.com
P: 203-854-7776 / F: 203-854-7934
137 East Avenue
Norwalk, CT 06851

December 6, 2021

Cabezas & DeAngelis LLC
78 Elm Street
Bridgeport, CT 06604

RE: 283 Richards Avenue – Sikh Religious Center


Dear Mr. DeAngelis,

The proposed subsurface sewage disposal plan for 283 Richards Avenue with revision date of December 3rd is approved with the following notes:

1. Septic tank, pump chamber and storage tank to be minimum 25ft from foundation drain installation
2. Maximum dosing volume – gallons per linear feet for GST 6218/6236 is as follows
 - (1 row) GST 6218 – $6.92\text{gal/lf} \times 40\text{lf} = 276.8$ gals
 - (2 rows) GST 6236 – $13.84\text{gal/lf} \times 75 = 1038$ gals (2076 gals total)

To account for different dosing volumes within the same row, a (9) nine-out distribution box will be installed separating the 40ft GST 6218 and the 75ft GST 6236 rows, with one pipe feeding the 40ft row and 4 pipes feeding the 75ft row. A second (9) nine-out distribution box will be installed for the second 75ft row of GST 6236 and will also be fed by 4 pipes.

Respectfully submitted,


Shaun Duffy
Registered Sanitarian